


Flexible CFPPs to Accommodate Rapid Penetration of Variable Renewable Energy


Raditya Wiranegara
Jakarta, 3 December 2025

CFPPs emissions mitigation initiatives




Source: analisis IESR dan Castlerock

IESR previous works on flexible CFPPs



[Link](#)



[Link](#)

An analogy for CFPP's flexible operation






Baseload



Flexible



Flexible operation parameters



Flexible operation means:

- **Lower** TML
- **Higher** ramp rates
- **Shorter** start-up times


... **relative** to each parameter at design points

Source: Agora Energiewende. (2017). Flexibility in Thermal Power Plants

Drivers for flexible CFPPs

- **Increasing share of renewables**, especially VREs, within the system
- **Lower cost of generation** of the renewables
- **Limited options** for balancing resources
- **Tighter regulations** on emissions and environment

Live Agorameter | Power generation and consumption



Source: Agora Energiewende, Live Agorameter, 2025

State-of-the-art of CFPPs flexible operation parameters

Technical Minimum Load (TML)

Power Plant Type	Most Used [% PNom]	State-of-the-Art [% PNom]
Hard Coal-Fired	25–40%	25–40%
Lignite-Fired	50–60%	35–50%

Ramp Rates

Power Plant Type	Most Used [%/min]	State-of-the-Art [%/min]
Hard Coal-Fired	1.5–4%	3–6%
Lignite-Fired	1–2%	2–6%


Start-up Time

Power Plant Type	Most Used	State-of-the-Art
Hard Coal-Fired	2.5 – 3 hours (Hot start)	80 minutes – 2.5 hours (Hot start)
	5 – 10 hours (Cold start)	3 – 6 hours (Cold start)
Lignite-Fired	4 – 6 hours (Hot start)	1.25 – 4 hours (Hot start)
	8 – 10 hours (Cold start)	5 – 8 hours (Cold start)


Source: analisis IESR dan Castlerock

CFPPs characteristics in Indonesia - age, capacity, and steam cycle technology

CFPP Units by Lifespan and Technology in Indonesia




CFPP Capacity by Lifespan and Technology in Indonesia




Source: analisis IESR dan Castlerock

Typical subsystems found in a CFPP



Source: Agora Energiewende. (2017). Flexibility in Thermal Power Plants

Recommended subsystems to be retrofitted for CFPs flexible



Source: Agora Energiewende. (2017). Flexibility in Thermal Power Plants

No.	Retrofit Options	Subsystems	Subcritical (500 MW)	Supercritical (750 MW)	Flexibility Objective*
1	Gas bypass to keep air heater warm	<ul style="list-style-type: none"> Steam, Water & Gas Cycle 	\$1.50M	\$3.00M	IRT, RML
2	Improved APH basket life with traveling APH blowers (to remove deposits before cycling down)	<ul style="list-style-type: none"> Steam Turbine System 	\$1.00M	\$1.00M	IRT, RML
3	Improved flame proving equipment for burners	<ul style="list-style-type: none"> Control & Communication Oil and Fuel Supply for Ignition Boiler 	\$1.00M	\$1.50M	IRT, RML, RST
4	Improved vibration sensing & monitoring	<ul style="list-style-type: none"> Control & Communication Boiler 	\$2.50M	\$3.50M	IRT, RML, RST
5	New valve operators (full arc / sliding pressure)	<ul style="list-style-type: none"> Steam, Water & Gas Cycle Steam Turbine 	\$1.80M	\$4.00M	IRT, RML, RST
6	Improved APH basket life with advanced materials (for wet flue gas cycling)	<ul style="list-style-type: none"> Steam Turbine System 	\$2.00M	\$2.00M	IRT, RML
*Notes: <ul style="list-style-type: none"> RML = Reduced Minimum Load; IRT = Increased Ramping Rate; RST = Reduced Start-up Time 					

Source: analisis IESR dan Castlerock, as quoted from Venkataraman, S. et al., Cost-Benefit Analysis of Flexibility Retrofits for Coal and Gas-Fueled Power Plants, NREL/SR-6A20-60862, 2014. <https://docs.nrel.gov/docs/fy14osti/60862.pdf>

Flexibility scenario tested

80% CF



- ☐ Baseload Operation
- ☐ No shares of renewable
- ☐ Optimum Emission Factor

65% CF



- ☐ Moderate Flexibility
- ☐ Medium shares of renewable
- ☐ Small increase of Emission Factor
- ☐ Not require investment
- ☐ Higher O&M cost
- ☐ Provide avoided carbon tax

Flexible without retrofit

40% CF



- ☐ Aggressive Flexibility
- ☐ High shares of renewable
- ☐ Highest Emission Factor
- ☐ Need significant investment
- ☐ Highest O&M cost
- ☐ Provide avoided carbon tax

Flexible with retrofit

Source: analisis IESR dan Castlerock

First study CFPP case: Subcritical, 575 MW, 28 y/o

Parameter	Units	Baseload (CF 80%)	Flexible without Retrofit (CF 65%)	Flexible with Retrofit (CF 40%)
Annual Electricity Generation	MWh/yr	4,029,600	3,274,050	2,014,800
Total O&M	USD/yr	35,714,400	34,728,407	32,843,310
Additional O&M	USD/yr	-	1,736,420	6,568,662
CAPEX Retrofit	USD	N/A	N/A	9,800,000
If Carbon Tax Applied:				
Annual Emission Produced	tCO ₂ e/yr	4,041,689	3,283,872	2,020,844
Specific Carbon Emission Cap	tCO ₂ e/MWh	0.911		
Max. Emission Cap	tCO ₂ e/yr	3,670,966	3,670,966	3,670,966
Taxable Emission	tCO ₂ e/yr	370,723	N/A	N/A
Domestic Carbon Tax Rate: 1.88 USD/tCO₂e				
Annual Carbon Tax Paid	USD/yr	695,106	N/A	N/A
Potential Avoided Carbon Tax Annually	USD/yr	N/A	695,106	695,106
International Carbon Tax Rate: 19 USD/tCO₂e				
Annual Carbon Tax Paid	USD/yr	7,043,741	N/A	N/A
Potential Carbon Tax Avoided Annually	USD/yr	N/A	7,043,741	7,043,741

Second CFPP study case: Supercritical, 813 MW, 13 y/o

Parameter	Units	Baseload (CF 80%)	Flexible without Retrofit (CF 65%)	Flexible with Retrofit (CF 40%)
Annual Electricity Generation	MWh/yr	5,697,504	4,629,222	2,848,752
Total O&M	USD/yr	50,497,056	49,102,948	46,437,584
Additional O&M	USD/yr	-	2,455,147	9,287,517
CAPEX Retrofit	USD	N/A	N/A	15,000,000
If Carbon Tax Applied:				
Annual Emission Produced	tCO ₂ e/yr	5,253,099	4,268,143	2,626,549
Specific Carbon Emission Cap	tCO ₂ e/MWh	0.911		
Max. Emission Cap	tCO ₂ e/yr	5,190,426	5,190,426	5,190,426
Taxable Emission	tCO ₂ e/yr	62,673	N/A	N/A
Domestic Carbon Tax Rate: 1.88 USD/tCO₂e				
Annual Carbon Tax Paid	USD/yr	117,511	N/A	N/A
Potential Carbon Tax Avoided Annually	USD/yr	N/A	117,511	117,511
International Carbon Tax Rate: 19 USD/tCO₂e				
Annual Carbon Tax Paid	USD/yr	1,190,778	N/A	N/A
Potential Carbon Tax Avoided Annually	USD/yr	N/A	1,190,778	1,190,778

Benefits from the perspective of system operator, in this case PLN

Case Study	Reference Price	Cost of generation (USD/year)		
		CF 80%	CF 65%	CF 40%
Subcritical 575 MW	DMO	209.539.200	(4.608.855)	(12.290.280)
	International market price	239.864.918	(21.093.967)	(56.250.580)
Supercritical 813 MW	DMO	346.620.920	(17.092.512)	(45.580.032)
	International market price	396.785.893	(12.330.171)	(32.880.455)

The calculation above assumed the energy loss due to the flexible operation is replaced by solar PV

Source: analisis IESR dan Castlerock

Another benefit...

Scenario	CFPP 100 MW	CFPP 600 MW
High solar irradiance	354.000.000 IDR	2.120.000.000 IDR
Low solar irradiance	265.000.000 IDR	1.590.000.000 IDR

- Reduce the start-up/shutdown → Reduce High Speed Diesel (HSD)
- Assumptions:
 - HSD price: 10.600 – 14.150 IDR/litre
 - HSD usage during start-up:
 - CFPP100 MW: 25.000 litre
 - CFPP 600 MW: 150.000 litre.

Source: IESR. (2022). Flexible Thermal Power Plant: An Analysis of Operating Coal-Fired Power Plants Flexibly to Enable the High-Level Variable Renewables in Indonesia's Power System

Recommendations

- **Phased Emission Reduction:**
 - Supplementary strategy to CFPPs phase-out.
 - Low-utilization high-value operations.
- **Leverage Flexibility for Grid Stability:**
 - Ancillary services becomes critical in a high VRE-share system.
 - CFPPs, through retrofitting and operational adjustments, could fit in the role, ensuring grid adequacy and security.
- **Manage Financial and Regulatory Hurdles:**
 - A review and amendment of existing PPAs is necessary.
 - The most opportune time for these investments is after debt repayments have been completed and higher tariffs can be negotiated to recover costs.
- **Prioritize Older and Less Efficient Units:**
 - Focus on subcritical and supercritical CFPP units as they make up the majority of Indonesia's fleet.
 - Already at a stage where flexibility upgrades are most relevant and cost-effective.

Thank you

Accelerating Low Carbon
Energy Transition

 www.iesr.or.id

 [iesr.id](https://www.facebook.com/iesr.id)

 [iesr.id](https://www.instagram.com/iesr.id)

 [IESR](https://twitter.com/IESR)

 [iesr](https://www.linkedin.com/company/iesr)